




UNLESS OTHERWISE APPROVED ALLOWABLE LOAD ON UPPER ATTACHMENT IS 1/4 OF FAILURE LOAD.  
UPPER ATTACHMENTS MAY BE TO WOOD STRUCTURES ALSO.




FLAT BAR CONCRETE INSERT





MANUFACTURED CONCRETE INSERTS



3




WASHER MAY BE OMITTED WITH  
100 LB (45 KG) MAX LOAD ON  
22 GA (0.85 mm) STRAP WHEN  
FOLDED



6a C-CLAMP W/ RETAINING CLIP OR  
6b C-CLAMP W/ LOCK NUT (OPTIONAL)


A HANGER STRAP MAY ALSO BE C  
CLAMPED TO THE STRUCTURAL FLANGE



EXPANSION SHIELDS


EXPANSION NAIL

CONCRETE ANCHORS




POWER ACTUATED  
STUDS INTO STEEL  
(STRUCTURE OR DECK)

WIRE USE IS NOT  
PRECLUDED BY THESE  
ILLUSTRATIONS



WELDED STUDS



FRiction CLAMPS

\* IMPORTANT! PREVENT BENDING OF  
STRAP AT 90° BEND UNDER LOAD.

THE NUMBERS ASSOCIATED WITH THE ART ARE  
ONLY FOR CONVENIENT REFERENCE.